

To: Dunbar C Regis[Dunbar.Regis@dcwater.com]
From: Graham, Allison
Sent: Fri 6/20/2014 8:42:41 PM
Subject: RE: CCTV Results

Hi Mr. Regis –

Thanks so much for following up. I will take a look and let you know if I have any questions.

Thanks again!

Sincerely,


Allison

From: Dunbar C Regis [mailto:Dunbar.Regis@dcwater.com]
Sent: Friday, June 20, 2014 4:30 PM
To: Graham, Allison
Subject: RE: CCTV Results

Allison:

Without copying the CCTV reports, our findings:

There was no lateral connection to the 27" storm line on S Street, SW side. We found one lateral connection that appeared to be coming from the building – 1711 1st Street, SW (S Street side) on the 12" sanitary line at about 23 feet from the downstream manhole. There were a few other lateral connections tying into the 12" sanitary line on the First Street side of the property, but they appeared to be inactive. (see Sewer Map attached – sanitary sewer is in red and storm sewer is in blue).



Dunbar Regis, PE | Manager | Department of Sewer Services | District of Columbia Water and Sewer Authority | dregis@dcwater.com | 125 O Street, SE | Washington, DC 20003 | (202) 264-3829 (office) | (202)-264-3845 fax



Water is Life! | [Web](#) | [Facebook](#) | [Twitter](#) | [YouTube](#) | [Flickr](#)

From: Graham, Allison [<mailto:Graham.Allison@epa.gov>]
Sent: Thursday, June 19, 2014 3:17 PM
To: Dunbar C Regis
Subject: CCTV Results

Dear Mr. Regis,

I hope this email finds you well. I know that we've been playing phone tag for a few weeks now, so I figured I would follow up with you via email. You stated that your team CCTV'd the sanitary and storm sewer lines near the Super Salvage Property located at 1711 1st St. SW, Washington, DC 20024. I was hoping that you could share your results of that effort with me. Please let me know if this is possible, and if so, maybe we can discuss the best method to share this information. Thank you in advance!

Sincerely,

Allison

Allison M. Graham, E.I.T.
Environmental Engineer
NPDES Enforcement Branch

U.S. EPA Region III, Water Protection Division
Office of Permits & Enforcement
1650 Arch Street (3WP42)
Philadelphia, PA 19103-2029
Phone: (215) 814-2373
Fax: (215) 814-2318

IMPORTANT NOTICE: The security of electronic mail sent through the Internet is not guaranteed. DC WATER therefore recommends that you do not send confidential information to us via electronic mail, including social security numbers, account numbers, and personal identification numbers unless instructed to do so through a secured site. Delivery, and timely delivery, of electronic mail is also not guaranteed. DC WATER also recommends that you do not send time-sensitive or action-oriented messages to us via electronic mail unless instructed to do so.